

Sewer and Utility Report – May 27, 2019

Andrew and Eddy Van derveldon had a meeting to discuss the treatment plant (ponds + U.V.)

There are a number of items that we'll need to fix/address this year

- stairs/cover to the chamber need to be replaced (pricing to do so is underway)
- There are 8-10 lamps/bulbs that need to be ordered for the U.V. system
- There are trees around the fence/lagoons that need to be cut/removed to prevent damage to the lagoon liner
- Eddy mentioned we should have the lagoon cells sludge checked. It's been 17 yrs since the original lagoon has been checked
- Andrew mentioned a little building on the U.V. chamber to allow tool/material storage for the treatment plant.
- Eddy mentioned we should have a gas detector for personal safety for entering the U.V. chamber.
- A new stainless steel sump pump needs to be ordered for the sump of the U.V. chamber.
- There is periodic jet pump/truck work that Eddy does as preventative maintenance within the manholes/lagoons
- Eddy mentioned we should contact any local businesses to determine if their grease traps are working or not, or have one installed, and to remind residents not to pour grease down the drains.

Andrew has also contact Luv van Hal with WSP, who is familiar with our town/system/pipe network, this is to discuss the stormwater management plan, and to discuss sidewalks west along Anderson road to the edge of the village limits.

Andrew had a meeting with Luc from WSP on the following topics.

- Storm water issues in the community.

Luc advised that we speak with the province, because they are aware that this is an issue. (Andrew sent email to Mark Sherren to discuss issues)

Luc advised if we were to proceed with the sidewalk extension, further stormwater network would need to be installed along the south of Anderson rd. Province requires this if a sidewalk is added to the existing roadway.

-Sidewalk extension west.

Luc provided andrew with a cost estimate of the sidewalk extension along anderson to the west of the community. Total estimates were 700k. Council to look into the cost and determine best course of action here.

- Lagoon questions etc

Luc agreed that it maybe time to investigate how well the treatment plant is working. Inital test would be to gather samples of the sludge to figure out cost estimates of the lagoon cleaning.

- Digital plans.

Luc is going to send all of the plans Delcom/Genivar/WSP has done for the community to us for our files.

Any questions let me know.

Andrew McCardle